



Overhead Service provided and installed by CVEC

Mast type weatherhead

3' max

2" OR 3" GALVANIZED PIPE

16'

Meter Base

48" - 72"

Final Grade

8' ground rod, clamp and #6 bare copper ground wire
 (Supplied and installed by consumer)
 Grounding conductor shall be connected from the ground
 lug in meter base to the ground rod(s)
 Cooperative requires the meter base to be grounded

**PERMANENT OVERHEAD SERVICE TO
 STRUCTURE FROM CVEC POLE TO MAST
 (400 AMP MAX)**



CENTRAL VIRGINIA
 ELECTRIC COOPERATIVE

11/27/2012