



CVEC's existing or Proposed pole

Consumer to provide all material except for meter base and meter

PERMANENT OVERHEAD SERVICE POLE WITH H-STRUCTURE (MAX 400A)
(Service Pole must be within 10 feet of CVEC Pole)



CENTRAL VIRGINIA
ELECTRIC COOPERATIVE

12/04/2012