

THIS INSTALLATION APPLIES TO ALL SINGLE AND MULTI-FAMILY DWELLING STRUCTURES AND ACCESSORY BUILDINGS. IF SERVICE WIRE WILL BE CROSSING A DRIVEWAY THEN ATTACHMENT HEIGHT NEEDS TO BE 16'. IF 16' CAN NOT BE OBTAINED THAN A MAST WILL NEED TO BE INSTALLED.

CVEC WILL PROVIDE THE POINT OF ATTACHMENT DEVICE

OVERHEAD SERVICE PROVIDED AND INSTALLED BY CVEC

SERVICE ENTRANCE CABLE PROVIDED AND INSTALLED BY CUSTOMER.

METER SOCKET PROVIDED BY CVEC AND INSTALLED BY CUSTOMER. METER LOCATION MUST BE OBTAINED FROM CVEC FOR ALL NEW SERVICES AND SERVICE UPGRADES

48" - 72"

FINAL GRADE

8' ground rod, clamp and #6 bare copper ground wire
(Supplied and installed by consumer)
Grounding conductor shall be connected from the ground lug in meter base to the ground rod(s)
Cooperative requires the meter base to be grounded

TYPICAL RESIDENTIAL OVERHEAD SERVICE ON HOUSE, SINGLE METER



**CENTRAL VIRGINIA
ELECTRIC COOPERATIVE**

12/04/2012