



Cooperative to install cable  
 Consumer to provide all ditches per Cooperative's specifications  
 Using a CVEC approved contractor will enable cable to be installed at the same time the ditch is dug.

When conduit is required, consumer to provide pull rope.

3" Conduit  
 (Cooperative will install)

8' ground rod, clamp and #6 bare copper ground wire  
 (Supplied and installed by consumer)  
 Grounding conductor shall be connected from the ground lug in meter base to the ground rod(s)  
 Cooperative requires the meter base to be grounded

**PERMANENT UNDERGROUND SERVICE TO  
 STRUCTURE WITH PRIMARY AND SECONDARY  
 (400 AMP MAX)**



CENTRAL VIRGINIA  
 ELECTRIC COOPERATIVE

11/07/2012