



Cooperative to install cable from Pole to meter base  
Consumer to provide a ditch per Cooperative's specifications

When conduit is required, consumer to provide pull rope.

**PERMANENT UNDERGROUND SERVICE TO  
STRUCTURE FROM CVEC POLE  
(400 AMP MAX)**



CENTRAL VIRGINIA  
ELECTRIC COOPERATIVE

11/27/2012